

DELHI DEVELOPMENT AUTHORITY
OFFICE OF THE CHIEF ENGINEER (SEZ)
SHAHPUR JAT, NEW DELHI

No.CE(SEZ)/12(2)07/51/RTI/ 748

Dated : 12-3-07

To

✓
Sh. Rejiman C.K
Nav Sansad Vihar, RWA
Plot No-4, Sector-22, Dwarka
New Delhi-110 075

Sub: Information required under RTI Act-05, your application dated 21-02-07, received in this office on 23-02-07

In this regard, information as received from concerned office is as under :

1. The reply to letter dated 2.12.05 has not been sent, however, the issues raised in the said letter are same and covered under reference dated 6.12.06 which has been replied vide office letter no.F-8(48)/CC16/DDA/320 dated 9.3.07
2. The reply of letter dated 6.12.06 has been given vide letter no.320 dated 9.3.07
3. There is no deviation from original plan, the crossing of Pushpanjali Farms (Express line road – NH-8, Shiv Murty to underpass Dwarka) has been given as per approved plan issued by competent authority.
4. There is no deviation in the plan.
5. No comments.
6. Requisite answers furnished vide letter No.320 dated 9.3.07
7. The quality check was conducted by the then EE/SED-12 and welding of joints were satisfactory but due to high speed of traffic, the welding joints could not withstand the pressure. The steel grating over catch drains now has been got designed from the consultant for the traffic which is coming at a speed of 80-100 kms. against the required speed of 50-60 kms. as per IRO norms and action is in progress by the Flyover Division No.1.
8. A boundary wall along the periphery of service road between Airport Authority land has been constructed by DDA to stop flow of water from Airport Authority land, besides a 450mm dia RCC has also been laid for disposal of rain water towards Dwarka side to Village Bharthal George. Recently, the work has been transferred to Flyover Division No.1, DDA.
9. The maintenance of the road/service roads are under the charge of Flyover Division No.1
10. No permission has been given to Farm Houses for parking of vehicles along the service road, use of generator and tent houses.
11. Regarding violation of traffic on main road, Delhi Police/ Traffic Police, may be contacted.

Appellate Authority is C.E.(SEZ), DDA, Shahpurjat, New Delhi (26497420)

Cen
12/3/07
(V.K. Aggarwal)
S.E.(HQ)/SEZ/PIO
(Ph.No.26491227)

Copy to :-

1. CE(SEZ) for information.
2. SE/CC-16 w.r.to letter no.320 dated 9.3.07

✓
S.E.(HQ)/SEZ/PIO
(Ph.No.26491227)